

FIREFIGHTER II SKILLS EVALUATION SHEETS

SS #	Skill Sheet Title	NFPA 1001 Objectives Addressed 2008 Edition
5.1.2.1A	Donning PPE and SCBA	5.1.2.1, 5.1.2.1.(3)(C)
5.1.2.1B	Doffing SCBA	5.1.2.1, 5.1.2.1.(3)(C)
6.2.1A	Complete a Basic Incident Report	6.2.1, 6.2.1(B)
6.2.2A	Communicate the Need for Assistance	6.2.2, 6.2.2(B)
6.3.1A	Foam Stream Application	6.3.1, 6.3.1(B)
6.3.1B	Fire Suppression – Open Pans of Combustible Liquids (with water)	6.3.1, 6.3.1(B)
6.3.1C	Open Liquid fires	6.3.3, 6.3.3(B)
6.3.2A	Interior Attack – Below Grade	6.3.2, 6.3.2(B), 6.2.2, 6.2.2(B)
6.3.2B	Interior Attack – Above Ground	6.3.2, 6.3.2(B), 6.2.2, 6.2.2(B)
6.3.2C	Interior Attack – Grade Level	6.3.2, 6.3.2(B), 6.2.2, 6.2.2(B)
6.3.3A	Flammable Gas Cylinder	6.3.3, 6.3.3(B)
6.3.4A	Preserve Evidence of Cause and Origin	6.3.4, 6.3.4(B)
6.4.1A	Vehicle Extrication	6.4.1, 6.4.1(B)
6.4.1B	Cribbing and Shoring	6.4.1, 6.4.1(B)
6.4.2A	Rescue Team Assistance	6.4.2, 6.4.2(B), 6.4.1(B)
6.5.1A	Private Dwelling Inspection	6.5.1, 6.5.1(B)
6.5.2A	Program Presentation	6.5.2, 6.5.2(B)
6.5.2B	Prepared Documentation	6.5.2, 6.5.2(B)
6.5.3A	Prepare a Pre-Incident Survey	6.5.3, 6.5.3(B)
6.5.4A	Portable Power Plant Maintenance	6.5.4, 6.5.4(B)
6.5.4B	Power Tool Selection	6.5.4, 6.5.4(B), 6.4.1(B)
6.5.5A	Annual Service Test	6.5.5, 6.5.5(B)



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 5.1.2.1A	Primary Task: Donning Personal Protective Clothing and Self Contained Breathing Apparatus
Objective(s) : 5.1.2.1, 5.1.2.1 (3)(c)	NFPA Standard: 472
Candidate # <input style="width: 50px;" type="text"/>	
Performance Evaluation Sheet	
Tasks :	
	1st 2nd
1 Boots and Trousers	<input type="checkbox"/> <input type="checkbox"/>
2 * Coat (buttoned or fastened completely, collar turned up)	<input type="checkbox"/> <input type="checkbox"/>
3 * Checks cylinder gauge (should be 90% full)	<input type="checkbox"/> <input type="checkbox"/>
4 * Opens cylinder fully	<input type="checkbox"/> <input type="checkbox"/>
5 Dons SCBA harness	<input type="checkbox"/> <input type="checkbox"/>
6 * Dons facepiece and checks seal	<input type="checkbox"/> <input type="checkbox"/>
7. Confirms positive pressure	<input type="checkbox"/> <input type="checkbox"/>
8 Activates PASS device (if applicable)	<input type="checkbox"/> <input type="checkbox"/>
* Critical Task Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
Total number tasks candidate must complete to pass	
6	

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 5.1.2.1B	Primary Task: Doffing Self Contained Breathing Apparatus (SCBA)		
Objective(s) : 5.1.2.1, 5.1.2.1(3)(c)	NFPA Standard: 472	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Deactivate Positive Pressure if Required		
2	Closes cylinder fully		
3	* Breathes off excess air, closes remaining valves (if applicable)		
4	Disconnect regulator from facepiece		
5	Removes facepiece, buckles and straps properly		
6	* Gently lowers unit to ground or case		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.2.1A	Primary Task: Complete Basic Incident Report		
Objective(s) : 6.2.1, 6.2.1(A)(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Records department FDID, and incident number		
2	* Records number of personnel responding		
3	Records Officer in charge (OIC)		
4	Records name and address of occupant/owner		
5	* Records type of structure		
6	* Records type of incident		
7	* Records type of action taken		
8	Records damage estimate		
9	Records remarks/comments		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			6

1/10/11

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.2.2A	Primary Task: Communicate the Need for Assistance		
Objective(s) : 6.2.2, 6.2.2(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	Demonstrates knowledge of alarm assignment SOP's (if applicable)		
	a) alerting procedures		
	b) incident assignments		
	c) fireground reports		
2	Demonstrates procedures for requesting additional response or resources		
3	Demonstrates knowledge of radio traffic procedures		
4	Demonstrates evacuation signal procedures		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			3

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.3.1A	Primary Task: Foam Stream Application		
Objective(s) : 6.3.1, 6.3.1(A)(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Wears appropriate protective clothing properly		
2	* Assembles foam appliances and / or equipment		
3	* Matches nozzle to eductor		
4	Introduces eductor to foam concentrate		
5	Identifies fuel type (hydrocarbon or polar solvent)		
6	Sets the eductor metering valve to proper concentrate percentage rating		
7	Opens nozzle properly		
8	* Applies foam by demonstrating appropriate method as directed		
9	Establishes an adequate vapor suppression blanket		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 6

1/10/11

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.3.1B	Primary Task: Fire Suppression – Open Pans of Combustible Liquids (with water)		
Objective(s) : 6.3.1, 6.3.1(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Wears approved full protective equipment with SCBA correctly		
2.	Describes the volume of water needed (extinguishment and reach)		
3	* Approaches liquid using wide fog pattern		
4	* Avoids stepping into pools of fuel and fuel runoff		
5	Locates and operates shut-off valve (where applicable)		
6	Retreats using wide fog pattern		
7	Follows all safety precautions		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.3.1C	Primary Task: Open Liquid Fires	
Objective(s) : 6.3.1, 6.3.1(B)	NFPA Standard: 1001	Candidate #
Performance Evaluation Sheet		
Tasks :		
		1st 2nd
1	* Wears approved full protective equipment with SCBA correctly	
2	Selects appropriate nozzle	
3	Approaches fire, maintaining team communication	
4	Operates fog nozzle on approach (wide fog pattern, if applicable)	
5	* Opens nozzle fully	
6	Extinguishes fire	
7	Executes effective retreat with wide fog pattern	
8	Follows all safety precautions	
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT
		Total number tasks candidate must complete to pass 6

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.3.2A	Primary Task: Interior Attack – Below Grade		
Objective(s) : 6.3.2, 6.3.2(B), 6.2.2, 6.2.2(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Wears full protective clothing and SCBA correctly		
2	* Follows proper radio procedures. Radios command post of situation		
3	Uses appropriate carry. Carries sufficient hose to burn area		
4	Flakes hose out prior to descending stairs		
5	* Descends stairs safely (feet first)		
6	Uses proper radio procedures. Radios pump operator to charge line		
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.3.2B	Primary Task: Interior Attack – Above Ground		
Objective(s) : 6.3.2, 6.3.2(B), 6.2.2, 6.2.2(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Wears full protecting clothing and SCBA correctly		
2	* Uses proper radio procedures. Radios command post of situation		
3	Raises 24' / 35' extension ladder and checks for proper climbing angle		
4	Ensures that ladder is butted, secured, and locks are seated		
5	With appropriate carry, carries sufficient hose to a 2 nd . floor room to operate		
6	Uses proper radio procedures. Radio pump operator to charge line		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.3.2C	Primary Task: Interior Attack – Grade Level		
Objective(s) : 6.3.2, 6.3.2(B), 6.2.2, 6.2.2(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Wears full protecting clothing and SCBA correctly		
2	* Follows proper radio procedures. Radios command post of situation		
3	Uses appropriate carry. Carries sufficient hose to burn area		
4	Flakes hose out prior to entering burn area		
5	Uses proper radio procedures. Radios pump operator to charge line		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.3.3A	Primary Task: Flammable Gas Cylinder		
Objective(s) : 6.3.3, 6.3.3(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Wears approved full protective equipment and SCBA correctly		
2	Selects appropriate nozzle		
3	* Approaches fire (wide fog pattern) maintaining team communication		
4	Operates fog nozzle on approach (wide fog pattern, if applicable)		
5	* Closes shutoff valve		
6	Executes effective retreat (wide fog pattern, if applicable)		
7	* Follows all safety precautions		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL
Fire Fighter II



Skill Sheet No. 6.4.1A	Primary Task: Vehicle Extrication		
Objective(s) : 6.4.1A, 6.4.1(A)(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Wears approved full protective clothing (eye protection) correctly	<input type="checkbox"/>	<input type="checkbox"/>
2	Secures scene	<input type="checkbox"/>	<input type="checkbox"/>
3	Communicates potential hazards at incident	<input type="checkbox"/>	<input type="checkbox"/>
4	Confirms vehicle is stabilized	<input type="checkbox"/>	<input type="checkbox"/>
5	* Protects victim	<input type="checkbox"/>	<input type="checkbox"/>
6	Communicates with victim	<input type="checkbox"/>	<input type="checkbox"/>
7	* Follows all safety procedures	<input type="checkbox"/>	<input type="checkbox"/>
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 5

1/10/11

**Prevent or prohibit any unsafe acts.
 Contact the Chief Examiner at any time with any questions.
 Remember, you are an evaluator, not a trainer...**

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR MUST COMPLETE REVERSE SIDE.



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.4.1B	Primary Task: Cribbing and Shoring		
Objective(s) : 6.4.1, 6.4.1(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Wears approved full protective clothing (eye protection) correctly	<input type="checkbox"/>	<input type="checkbox"/>
2	Selects proper pieces (wood) for cribbing	<input type="checkbox"/>	<input type="checkbox"/>
3	Places pieces into psition	<input type="checkbox"/>	<input type="checkbox"/>
4	* Checks stabilization	<input type="checkbox"/>	<input type="checkbox"/>
5	* Observes safety procedures		
	Proper lifting techniques when cribbing vehicle (back to vehicle)	<input type="checkbox"/>	<input type="checkbox"/>
	Proper hand placement when cribbing vehicle	<input type="checkbox"/>	<input type="checkbox"/>
* Critical Task	Failure of this task mandates failure on the entire objective	Safety is PARAMOUNT	Total number tasks candidate must complete to pass 4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.4.2A		Primary Task: Rescue Team Assistance	
Objective(s) : 6.4.2, 6.4.2(B), 6.4.1(B)		NFPA Standard: 1001	Candidate #
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Wears approved full protective equipment with eye protection correctly	<input type="text"/>	<input type="text"/>
2	Identifies and retrieves various types of rescue tools upon request	<input type="text"/>	<input type="text"/>
3	Establishes public barriers	<input type="text"/>	<input type="text"/>
4	Recognizes hazards	<input type="text"/>	<input type="text"/>
5	Assists rescue teams as a member of a team upon request	<input type="text"/>	<input type="text"/>
6	* Follows safety procedures	<input type="text"/>	<input type="text"/>
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.5.1A	Primary Task: Private Dwelling Inspections		
Objective(s) : 6.5.1, 6.5.1B	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	* Have and wear appropriate identification		
2	* Obtains permission from occupant		
3	Checks heating appliances		
4	Checks electrical distribution and appliances		
5	Checks cooking appliances		
6	Checks for smoking materials		
7	Checks attic and basement areas		
8	Checks yard and exterior areas		
9	Checks attached and detached buildings		
10	Communicates findings to occupant/exit interview		
11	Follows proper procedures and record keeping		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			8

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.5.2A	Primary Task: Preparation of Documentation		
Objective(s) : 6.5.2, 6.5.2(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	Identify program title		
2	Document participants by:		
	Name		
	Number		
3	Enter student evaluations		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
		Total number tasks candidate must complete to pass	
		3	

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.5.2B	Primary Task: Presentation of a Prepared Program		
Objective(s) : 6.5.2, 6.5.2(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	Selects lesson plan for topic and audience		
2	Maintains proper appearance		
3	Introduces self		
4	Introduces topic		
5	Presents lesson		
6	Answers questions		
7	Summarizes lesson		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			5

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.5.3A	Primary Task: Prepare a Pre-Incident Survey		
Objective(s) : 6.5.3, 6.5.3(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	Identifies components of the fire suppression system		
2	Identifies components of the fire detection system (if applicable)		
3	Prepares a site sketch		
4	Prepares a building sketch		
5	Identifies special features, hazards, and considerations (if applicable)		
6	Identifies type of occupancy		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.5.4A	Primary Task: Portable Power Plant Maintenance		
Objective(s) : 6.5.4, 6.5.4(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	Maintains / services properly		
2	Checks gas / fuel		
3	Checks Oil		
4	Starts properly		
5	Shuts down properly		
6	Demonstrates knowledge of applicable safety devices / equipment		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
		Total number tasks candidate must complete to pass	4

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE



State of Connecticut
COMMISSION ON FIRE PREVENTION AND CONTROL



Firefighter II

Skill Sheet No. 6.5.5A	Primary Task: Annual Service Test		
Objective(s) : 6.5.5, 6.5.5(B)	NFPA Standard: 1001	Candidate #	
Performance Evaluation Sheet			
Tasks :			
		1st	2nd
1	Uses 300 ft. of hose		
2	Tightens all connections		
3	Removes all air from lines		
4	Test hose to NFPA 1962		
5	Tests at required pressure for 3 minutes		
6	Checks all couplings for hose movement		
7	Uses pressure relief device as appropriate		
8	Records test results		
* Critical Task Failure of this task mandates failure on the entire objective		Safety is PARAMOUNT	
Total number tasks candidate must complete to pass			6

Prevent or prohibit any unsafe acts.
 Contact the Lead Evaluator at any time with any questions.
 Remember, you are an evaluator, not a trainer...

IN THE EVENT OF FAILURE OF THIS SKILL, EVALUATOR COMPLETE REVERSE SIDE