

**LOWER LEVEL RENOVATIONS
80 WASHINGTON STREET
HARTFORD, CONNECTICUT
PROJECT: BI- 2B – 029B**

BID OPENING	1:00 P.M.	DECEMBER 12, 2007
ADDENDUM NUMBER 1	DATE OF ADDENDUM	DECEMBER 3, 2007

The following clarifications are applicable to drawings and specifications for the project referenced above.

Item 1

Reference Drawing C-1.Existing vehicle entrance gate, card reader and vehicle detection loop are to remain. It shall be the Contractor's responsibility to maintain the gate in good working order for the duration of the project.

Item 2

Reference Drawing C.1.MC cable can be used to hang temporary utility lights (type C1) only.

Item 3

Reference Drawing D-101, A-102.The 6" base and 8" base are to be replaced as shown on the drawings.

Item 4

Reference Drawing D-101.No material is to be salvaged.

Item 5

Reference Drawing C.1.Provide 8'-0" high fence as specified.

Item 6

Reference Drawing C.1.There is no fence gate to Cedar Street

Item 7

Reference Drawing A-202, M-202.No metal guide rail is required.

Item 8

Reference Drawing A-602.Underside of canopy roof deck does not need to be fireproofed.