



# STATE OF CONNECTICUT

## DEPARTMENT OF PUBLIC HEALTH

May 11, 2009

Richard E. Couch, P.E.  
S-Box, LLC  
56 Olympus Parkway  
Middletown, CT 06457

### **Re: H-20 Wheel Loading Details & Specifications for the SB1 Series, S-Box Leach Field Proprietary Leaching System**

Dear Mr. Couch:

This program has received H-20 wheel loading details and specifications for the SB1 Series, S-Box Leach Field proprietary leaching system dated May 6, 2009. The submittal authorizes placement of the SB1 Series, S-Box Leach Field proprietary leaching system in vehicular travel areas when installed in accordance with the submitted documentation.

Within the H-20 loading details, the usage of a Geogrid product is noted as well as a specified depth of cover material over the system. This office will include the SB1 Series, S-Box Leach Field proprietary leaching system on our list of proprietary leaching systems that have submitted H-20 load rated supporting documentation.

If you have any questions, please contact me at (860) 509-7296.

Sincerely,

Matthew A. Pawlik, P.E., R.S.  
Sanitary Engineer III  
Environmental Engineering Program

Cc: John M. Laudano, R.S., S-Box, LLC, 56 Olympus Parkway, Middletown, CT 06457  
Robert W. Scully, P.E., Supervising Sanitary Engineer, EEP, DPH

Phone: (860) 509-7296



Telephone Device for the Deaf: (860) 509-7191  
410 Capitol Avenue - MS #51-SEW  
P.O. Box 340308 Hartford, CT 06134

*Affirmative Action / An Equal Opportunity Employer*